



ADDENDUM #3

ITB/RFP NUMBER: 2016033-PW-B

East Market Street Stormwater Improvements ITB

DATE: April 20, 2016

TO: All Potential Bidders/Offerors

City of Harrisonburg's East Market Street Stormwater Improvements ITB, is modified as follows:

1. Question: RSC Channel – (Christmas Ferns) What is the size at planting supposed to be?

Answer: Per Sheet C1-14, each plant should be a minimum of 5" high by 8" diameter (or width). This is typically a one gallon pot or similar.

2. Question: Dry Swale – (Pacific Blue Juniper, Blue Star Juniper, All Gold Juniper) What is the size at planting supposed to be?

Answer: Per Sheet C2-5, each plant should be a minimum of 5" high by 8" diameter (or width). This is typically a one gallon pot or similar.

3. Question: Regarding the Engineered Filtered Media - Are the specs laid out in section 2.05 the only specs there are? Is there a specified procedure for producing it (i.e. mixing bins and blending it through a pug mill)?

Answer: In addition to the specification 02350, section 2.05, aged mulch shall be defined as having decomposed for six months or longer. Contractor procedures will be reviewed and approved prior to the work, so as to create a uniformly blended mix with prescribed ratios of each media type. Specific mixing methods have not been provided.

All other requirements, terms and conditions of the ITB/RFP remain unchanged.

Addendum page must be signed and returned with your bid/proposal to acknowledge receipt of this addendum.

Authorized Signature

By: Pat Hilliard, CPPB
Procurement Manager